



Bulletin 160-P2 and 160-P3 CE Conformance

Reference

- Publication 0160-5.28ML dated September, 1999
- Publication 0160-5.29ML dated September, 1999

Issue

CE Conformance standards require control of radiated emissions (EMI).


Consequence

Without suppression, 160-CX cables used with 160-P2 (Bulletin 160 SSC™ Remote Keypad Module) and 160-P3 (Bulletin 160 SSC™ CopyCat Keypad Module) will exceed CE standards.

Solution

Add a ferrite bead to the 160-CX cables at the drive side of the cable.

Use Fair-Rite part number 0431164181 or equivalent with a complete turn as shown.



**Rockwell
Automation**