



Certificate of Compliance

Certificate: 1351952 (LR 1234-251C)

Master Contract: 150062

Project: 2307949

Date Issued: 2010/05/12

Issued to: Rockwell Automation, Inc./

Allen-Bradley
1201 South Second St
Milwaukee, WI 53204
USA
Attention: Paul Kowalsky

The products listed below are eligible to bear the CSA Mark shown



R. Tateishi, P. Eng.

Issued by: R. Tateishi, P. Eng.

PRODUCTS

CLASS 6225 01 - FUSEHOLDER ASSEMBLIES

Fuseholders, Bulletin 1491, for use in combination starters, 30-400A, 600V ac and less, suitable for Class H, Class K, Class R and Class J fuses.

Notes:

- Fuseholders, Cat Nos. 1491-N125, -N126, -N226, -N333, -N433, -N521 and -N621 are suitable for use on a circuit capable of delivering not more than 200 kA rms symmetrical amperes when Class J fuses are equipped.
- Fuseholders, Cat Nos. 1491-R125, -R226, -R126, -R266, -R333, -R433, -R523 and -R621 are suitable for use on a circuit capable of delivering not more than 200 kA rms symmetrical amperes when Class R fuses are equipped.

AB Drives



Certificate: 1351952 (LR 1234-251C)

Master Contract: 150062

Project: 2307949

Date Issued: 2010/05/12

- Fuseholders, Cat Nos. 1491-N321 and -N421 are suitable for use on a circuit capable of delivering not more than 10 kA rms symmetrical amperes when Class H fuses are equipped.
- Fuseholders, Cat No. 1491-N421 are suitable for use on a circuit capable of delivering not more than 10 kA rms symmetrical amperes when Class K fuses are equipped.

APPLICABLE REQUIREMENTS

CSA Std C22.2 No.	4248.1	-	Fuseholders, General Requirements
CSA Std C22.2 No.	4248.6	-	Fuseholders, Class H
CSA Std C22.2 No.	4248.8	-	Fuseholders, Class J
CSA Std C22.2 No.	4248.9	-	Fuseholders, Class K
CSA Std C22.2 No.	4248.12	-	Fuseholders, Class R