



Type Approval Certificate

Germanischer Lloyd

This is to certify that the undernoted product(s) has/have been tested in accordance with the relevant requirements of the GL Type Approval System.

Certificate No.	4083401 HH
Company	Rockwell Automation AG Buchserstrasse 7 5001 Aarau, SWITZERLAND
Product Description	Miniature circuit breaker
Type	1492-SP.B, 1492-SP.C, 1492-SP.D
Environmental Category	C
Technical Data / Range of Application	Rated operational current I_e (30°C): 0,5 - 63A AC Rated operational voltage U_e: 440V AC, 50/60Hz Rated operational voltage U_e: 250/500V DC*) Rated insulation voltage U_i: 440 Rated impuls withstand voltage U_{imp}:4000V Performance category : A Trip characteristic : B, C, D Rated short-circuit capacity Performance at : 440 V I_{cm}: 17kA (0,5 - 32A), 9kA (40 - 63A) I_{cu}: 10kA (0,5 - 32A), 6kA (40 - 63A) I_{cs}: 7,5kA (0,5 - 32A), 6kA (40 - 63A)
Test Standard	Regulations for the Performance of Type Tests Part 1, Edition 2003 IEC 60947-2(1989), IEC 60947-5-1(1991), IEC 60898 (1996)
Documents	Test report : CTI PA 724, CTI PA 811, Environmental test report FAZ, 10.01.2000
Remarks	None
Valid until	2017-10-03
Page	1 of 1
File No.	I.K.01
	Hamburg, 2012-10-04

Type Approval Symbol



Germanischer Lloyd

Wolfgang Voß

Harald Amberger

This certificate is issued on the basis of "Regulations for the Performance of Type Tests, Part 0, Procedure".

Allen-Bradley Motors