



# Certificate of Compliance

**Certificate:** 1587676 (LR 1234)

**Master Contract:** 150062

**Project:** 2305557

**Date Issued:** May 26, 2010

**Issued to:** Rockwell Automation, Inc./

Allen-Bradley  
1201 South Second St  
Milwaukee, WI 53204  
USA  
Attention: Mr. Robert Klobuchar

*The products listed below are eligible to bear the CSA Mark shown*



CSA B44.1/  
ASME-A17.5

*T. Munteanu*

**Issued by:** T. Munteanu, P.Eng.

## **PRODUCTS**

**CLASS 2411 01** - ELEVATOR EQUIPMENT-Open and Enclosed - Elevator Electrical Equipment

Open Type Solid State Motor Starters – Cat. Nos. 150-E, followed by 32, 51, 64, 74, 104, 147 or 234 followed by NCA or NCE, followed by FC; PCEC, followed by -032, -051, -064, -074, -104, -147 or -234, followed by -600V, followed by 120V or 230V; 50-07-0001, 50-07-0002, 50-07-0003, 50-07-0004, 50-07-0005, and 50-07-0006, rated 600V ac max, 3-ph, 50/60Hz; 85/147 Amps Maximum continuous current, 75/150 HP at 600 Vac, 10kA maximum short circuit ratings. Control voltage 120 or 240V ac, 1-ph, 50/60Hz.

Note: Open type devices are certified as components for use in other Certified equipment where the suitability of the combination is to be determined by CSA International.

## **APPLICABLE REQUIREMENTS**

Allen-Bradley



CSA INTERNATIONAL

**Certificate:** 1587676 (LR 1234)

**Master Contract:** 150062

**Project:** 2305557

**Date Issued:** May 26, 2010

---

CAN/CSA-C22.2 No. 14 - Industrial Control Equipment

CSA B44.1/ASME-A17.5 - Elevator and Escalator Electrical Equipment