

Power Standards Laboratory
www.PowerStandards.com
2020 Challenger Drive #100
Alameda, CA 94501 USA
TEL ++1-510-522-4400
FAX ++1-510-522-4455

SEMI F47-0706

Voltage Sag Immunity Compliance Certificate *Rockwell Automation Inc. / Allen Bradley 1606-XLS80E*

Input: AC100-240V 1-phase
Output: 80W, 24V, 3.3A

Description: Power Supply 24Vdc

Manufacturer: Rockwell Automation Inc. / Allen-Bradley

Manufacturer Address: 1201 South Second St. Milwaukee, WI 53204

Test Date and Location: 13 July 2005, 942 Corridor Park Blvd, Knoxville, TN 37932 USA

Tested configuration: 100% load, 50/60 Hz at 120/208 Vac, 1-Phase 2-wire +PE, S/N 358.920.38C

Pass/Fail criteria: Full rated output power and continuous processing during all voltage sags.

Certification:

1. Power Standards Laboratory certifies that the above power supply meets the requirements of SEMI F47-0706 for voltage sag immunity when tested according to the procedures set forth in IEC 61000-4-34. An IPC Voltage Sag Generator was used for the testing that fully complies with IEC 61000-4-34.



A handwritten signature in blue ink, appearing to read 'A. Eberhard', located below the PSL SEMI F47 logo.

Rockwell Automation/Allen-Bradley
Power Supply

Andreas Eberhard 16 April 2012
Power Standards Lab

Allen-Bradley Drives