



Certificate

Certificate no.

CU 72122211 01

License Holder:

Rockwell Automation
1201 South Second Street
Milwaukee WI 53204
USA

Manufacturing Plant:

Rockwell Automation
8155 Forsythia Street
Middleton WI 53562
USA

Test report no.: USA-RB 30881790 003

Client Reference: Dan Nachtigall

Tested to:

UL 61010-1:2004
CAN/CSA-C22.2 NO. 61010-1-04

Certified Product: Voltage Sag Detector

License Fee - Units

Model Designation: Allen-Bradley 1608S-3V480K,
Allen-Bradley 1608S-6V480K

7

Rated Voltage: AC 100-480V, 50/60Hz
Rated Current: 50mA
Protection Class: I


Special Remarks: Replaces Certificate CU72081496.

7

Appendix: 1, 1-3

Inh. = 713677 / Deb. = 713677 / Fert. = 754925

Licensed Test mark:



Signature

Date of Issue
(day/mo/yr)
24/08/2012

Dipl.-Ing. M. Glagla
QA Certification Officer

Certificate



Certificate no.

CU 72122211 02

License Holder:

Rockwell Automation
1201 South Second Street
Milwaukee WI 53204
USA

Manufacturing Plant:

Rockwell Automation
8155 Forsythia Street
Middleton WI 53562
USA

Test report no.: USA- 30881790 006

Client Reference: Dan Nachtigall

Tested to: UL 61010-1:2012
CAN/CSA-C22.2 NO. 61010-1-12

Certified Product: Voltage Sag Detector

License Fee - Units

Addition:

Model Designation: Allen-Bradley 1608S-3V480E

Change:

Upgrade of standard for all models: see above

Appendix: 1, 1-2

Licensed Test mark:



Date of Issue
(day/mo/yr)
16/07/2015