




Installation Instructions

ControlLogix Programmer Cable (Catalog Number 1756-CP3)


Contents

Use this document to install the 1756-CP3 cable. This cable connects the Logix 5550 or SLC family controllers to your DTE device.

Cable Wiring Diagram




Right-angle connector end of the cable




Cable Length
= 3 meters (118 in.)

Straight connector end of the cable




Install the Cable

1. Connect the right-angle connector end of the cable to your controller at the communications port.



2. Connect the straight connector end of the cable to your DTE device.



Allen-Bradley

 **Rockwell** Automation

Allen-Bradley

Worldwide representation.



Allen-Bradley Headquarters, 1201 South Second Street, Milwaukee, WI 53204 USA, Tel: (1) 414 382-2000
Fax: (1) 414 382-4444

Publication 1756-5.46 – May 1997

PN 955129-39

Copyright 1997 Allen-Bradley Company, Inc. Printed in USA