

# CERTIFICATE OF COMPLIANCE

**Certificate Number** 20150929-E194810  
**Report Reference** E194810-20120201  
**Issue Date** 2015-SEPTEMBER-29

**Issued to:** ROCKWELL AUTOMATION/ ALLEN-BRADLEY  
1 ALLEN-BRADLEY DR  
MAYFIELD HEIGHTS OH 44124

**This is to certify that  
representative samples of**

PROGRAMMABLE CONTROLLERS FOR USE IN  
HAZARDOUS LOCATIONS

Programmable Logic Controllers for use in  
Class I, Division 2, Groups A, B, C and D,  
Hazardous Locations

Programmable Controller: Cat. Nos. 1769-L16ER-BB1B,  
1769-L18ER-BB1B, 1769-L18ERM-BB1B, followed by  
Series A or B.

Have been investigated by UL in accordance with the  
Standard(s) indicated on this Certificate.

**Standard(s) for Safety:**


ANSI/ISA-12.12.01 -Nonincendive Electrical Equipment for  
Use in Class I and II, Division 2 and Class III, Div. 1 and 2  
Hazardous Locations  
C22.2 No. 213-M1987 -Non-Incendive Electrical Equipment  
for use in Class I, Division 2 Hazardous Locations

**Additional Information:**

See the UL Online Certifications Directory at  
[www.ul.com/database](http://www.ul.com/database) for additional information

Only those products bearing the UL Certification Mark should be considered as being covered by UL's  
Certification and Follow-Up Service.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please  
contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

