



Read This First

ATTENTION

24V dc FLEX I/O Thermocouple/mV Input Module (Cat. No. 1794-IT8)



ATTENTION: This thermocouple/mV module differs from previous versions of the module as follows:

- when sensing an open sensor, the module will indicate a **full upscale** reading for that particular sensor (for example, if a type B thermocouple has a maximum temperature of 1800°C, an open sensor results in a reading of 1800°C).

Make certain you monitor the overrange and underrange bits when a thermocouple indicates an upscale reading.

 **Rockwell** Automation

Allen-Bradley

With major offices worldwide.

World Headquarters,
Allen-Bradley,
1201 South Second Street,
Milwaukee, WI 53204 USA,
Tel: (1) 414 382-2000 Fax: (1) 414 382-4444

Pub. 1794-5.21-RN1 - December 1997

PN955128-89
Copyright 1997 Allen-Bradley Company, Inc. Printed in USA

AB Pa