



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

No. : 2005010307163529

NAME AND ADDRESS OF THE APPLICANT

Rockwell Automation, Inc.
1201 South Second Street, Milwaukee WI 53204, USA

NAME AND ADDRESS OF THE MANUFACTURER

Rockwell Automation, Inc.
1201 South Second Street, Milwaukee WI 53204, USA

NAME AND ADDRESS OF THE FACTORY

Rockwell Automation AG
Buchserstrasse 7, 5001 Aarau, Switzerland

NAME, MODEL AND SPECIFICATION

Circuit Breaker

140M-F...KT.7-45H... Ue: AC415V, 690V; 过电流脱扣器: 热磁式; In: 10A, 16A, 20A, 25A, 32A, 45A; Ics, Icu: 见附件; 使用类别: A; 极数: 3极脱扣级别: 10 辅助触头: Front
Mounting: AC-15: AC24V/4A, AC120V/3A, AC240V/1.5A; DC-
13: DC24V/2A, DC120V/0.5A, DC240V/0.25A; Right-side Mounting: AC-
15: AC24V/6A, AC120V/5A, AC240V/3A, AC415V/2A, AC690V/0.7A; DC-
13: DC24V/2A, DC120V/0.5A, DC240V/0.25A, DC415V/0.15A

THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB 14048.2-2008, GB 14048.4-2003

This is to certify that the above mentioned products have met the requirements of implementation rules for compulsory certification (REF NO. CNCA-01C-011:2007).

Date of issue: Dec. 31, 2010 Date of expiry: Dec. 31, 2015

Validity of this certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

Date of original certification: Oct. 27, 2005

This certificate can be verified through CNCA's website: www.cnca.gov.cn



President:

Wang Kejiao



CHINA QUALITY CERTIFICATION CENTRE

Section 9, No. 188, Nansihuan Xilu, Beijing 100070 P.R. China

<http://www.cqc.com.cn>

Q 0345604



中国国家强制性产品认证证书

附录:

第 1 页 共 1 页

证书编号: 2005010307163529

纸号: 345604

Rated Operational current I_e [A]	Thermal release Adjustment range [A]	Switching of 3 phase AC motors, AC-3 at 415VAC and 690VAC		I_{cu}	I_{cs}	Part Number (Allen Bradley)	Part Number (Sprecher+Schuh)
		3 phase [KW] (50Hz)		415V/690V			
		415 V	690 V	[KA]	[KA]		
140M-F8E Size 3, High break PLUS							
10	6.3...10	4.0	7.5	100/10	50/10	140M-F8E-C10	KTA7-45H-10A
16	10...16	7.5	13	100/10	50/10	140M-F8E-C16	KTA7-45H-16A
20	14.5...20	10	17	100/10	50/10	140M-F8E-C20	KTA7-45H-20A
25	18...25	11	22	100/10	50/10	140M-F8E-C25	KTA7-45H-25A
32	23...32	15	30	65/10	50/6	140M-F8E-C32	KTA7-45H-32A
45	32...45	22	40	65/10	50/6	140M-F8E-C45	KTA7-45H-45A
140M-F8N Size 3 (KTB7), High break PLUS							
25	25	11	22	100/10	50/10	140M-F8N-C25	KTB7-45H-25A
32	32	15	30	65/10	50/6	140M-F8N-C32	KTB7-45H-32A
45	45	22	40	65/10	50/6	140M-F8N-C45	KTB7-45H-45A
140M-F8T Size 3 (KTC7), High break PLUS							
25	18...25	11	22	65/10	50/6	140M-F8T-C25	KTC7-45H-25A
32	23...32	15	30	65/10	50/6	140M-F8T-C45	KTC7-45H-32A

注: 此附录与证书同时使用时有效。



主任:

中国质量认证中心

中国·北京·南四环西路188号9区100070

<http://www.cqc.com.cn>

