



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

No. : 2007010304233797

NAME AND ADDRESS OF THE APPLICANT

Rockwell Automation Inc.
1201 South Second Street, Milwaukee WI 53204, USA

NAME AND ADDRESS OF THE MANUFACTURER

Rockwell Automation Inc.
1201 South Second Street, Milwaukee WI 53204, USA

NAME AND ADDRESS OF THE FACTORY

ROCKWELL AUTOMATION MONTERREY MANUFACTURING CENTER S. DE R. L. DE C. V.
Camino Vecinal 3051, Parque Industrial PROMOFISA, Nuevo Leon 67110.

NAME, MODEL AND SPECIFICATION

Soft Starter

150-F... series, PF... series; Ith:625A, 780A, 970A, 1250A; Ue:AC200-400V,
AC200-500V, 230-690V; Ie:625A, 780A, 970A, 1250A; AC-53b; 3P

THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB 14048.6-2008

This is to certify that the above mentioned products have met the requirements of implementation rules for compulsory certification(REF NO. CNCA-01C-011:2007).

Date of issue: Jun. 11, 2010 Date of expiry: Mar. 11, 2015

Validity of this certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

Date of original certification: May. 25, 2007

This certificate can be verified through CNCA's website: www.cnca.gov.cn



President:

Wang Kejiao

CHINA QUALITY CERTIFICATION CENTRE

Section 9, No. 188, Nansihuan Xilu, Beijing 100070 P.R. China

<http://www.cqc.com.cn>



Q 0257696



中国国家强制性产品认证证书

附录:

第 1 页 共 2 页

证书编号: 2007010304233797

纸号: 257696

具体的型号标识:

Allen-Bradley 150-F Series 订货号编号规则

| | | | | | | | | | |
|-----|---|---|-----|---|---|---|---|---|---|
| 150 | - | F | 625 | N | C | D | B | - | 1 |
| 1 | | 2 | 3 | 4 | 5 | 6 | 7 | | 8 |

| | |
|---|--|
| 1 | Product Line 150-Solid state motor controller |
| 2 | Controller Type F-SMC Flex |
| 3 | Current Rating 625-625A 780-780A 970-970A 1250-1250A |
| 4 | Enclosure Type N-No enclosure,open-type |
| 5 | Input Voltage Rating B-200 to 400V ac C-200 to 500V ac Z-230 to 690V ac |
| 6 | Control Voltage Rating D-110 to 120V ac(625 to 1250A devices)(used initially then changed to A) A-100 to 120V ac(625 to 1250A devices) E-230 to 240V ac(625 to 1250A devices) |
| 7 | Control Options Blank-Standard B-Pump control D-Braking control |

注: 此附录与证书同时使用时有效。



主任:

中国质量认证中心

中国 · 北京 · 南四环西路 188 号 9 区 100070

<http://www.cqc.com.cn>





中国国家强制性产品认证证书

附录:

第 2 页 共 2 页

证书编号: 2007010304233797

纸号: 257696

Sprecher + Schuh PF Series 订货号编号规则

| | | | |
|--------|-------|-------|------|
| PF(X)- | -XXXX | -XXXX | -XXX |
| 1 | 2 | 3 | 4 |

| | |
|---|--|
| 1 | PFS:Solid-State Controller 交流半导体电动机控制器 PFB-Pump control 泵控制 PFD-Braking control 制动控制 |
| 2 | Code 代码 Description 代表含义 0625 625A 0780 780A 0970 970A 1250 1250A |
| 3 | 480V-Ue = 200-400V AC,3-phase,50Hz 600V-Ue = 200-500V AC,3-phase,50Hz |
| 4 | Blank 空缺-U _s = 110/120VAC(initially used then added suffix 120) 120-U _s = 110/120VAC 230-U _s = 230/240VAC |

The 150-F for Allen-Bradley is identical with PF Sprecher+schuh,except the nameplate.

注: 此附录与证书同时使用时有效。



主任:

中国质量认证中心

中国·北京·南四环西路188号9区 100070

<http://www.cqc.com.cn>

