



# CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

No. : 2008010307280128

## NAME AND ADDRESS OF THE APPLICANT

Rockwell Automation Inc.  
1201 South Second Street Milwaukee, WI53204 USA

## NAME AND ADDRESS OF THE MANUFACTURER

## NAME AND ADDRESS OF THE FACTORY

## NAME, MODEL AND SPECIFICATION

Moulded Case Circuit-Breaker  
140UE-L3, 140UE-L5, 140UE-L7 See the Appendix

## THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB 14048.2-2008

This is to certify that the above mentioned products have met the requirements of implementation rules for compulsory certification(REF NO. CNCA-01C-011:2007).

Date of issue: Feb.16,2011      Date of expiry: Mar.01,2015

Validity of this certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

Date of original certification: Jun.18,2008

This certificate can be verified through CNCA's website: [www.cnca.gov.cn](http://www.cnca.gov.cn)



President:

Wang Kejiao

**CHINA QUALITY CERTIFICATION CENTRE**

Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China

<http://www.cqc.com.cn>





# 中国国家强制性产品认证证书

附录:

第 1 页 共 1 页

证书编号: 2008010307280128

纸号: 357693

140UE-L3,140UE-L5,140UE-L7

热磁式:Ue:AC240V/415V/690V;DC250V;

In:250A,300A,320A,350A,400A,500A,600A,630A;

电子式:Ue:AC240V/415V/690V;In:250A,400A,600A,630A;

140UE-L3:AC240V:Ics:65kA;Icu:65kA;AC415V:Ics:35kA;Icu:35kA;

AC690V:Ics:6kA;Icu:12kA;DC250V(仅热磁式):Ics:22kA;Icu:22kA;

140UE-L5:AC240V:Ics:85kA;Icu:85kA;AC415V:Ics:50kA;Icu:50kA;

AC690V:Ics:10kA;Icu:20kA;DC250V(仅热磁式):Ics:22kA;Icu:22kA;

140UE-L7:AC240V:Ics:100kA;Icu:100kA;AC415V:Ics:70kA;Icu:70kA;

AC690V:Ics:13kA;Icu:25kA;DC250V(仅热磁式):Ics:42kA;Icu:42kA;

过电流脱扣器类型:热磁式,电子式;使用类别:A类;3P,4P

注: 此附录与证书同时使用时有效。



主任:

中国质量认证中心

中国·北京·南四环西路188号9区100070

<http://www.cqc.com.cn>

