



# CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

No. : 2008010307282409

## NAME AND ADDRESS OF THE APPLICANT

Rockwell Automation Inc.  
1201 South Second Street Milwaukee, WI53204 USA

## NAME AND ADDRESS OF THE MANUFACTURER

## NAME AND ADDRESS OF THE FACTORY

## NAME, MODEL AND SPECIFICATION

Moulded Case Circuit-Breaker  
140UE-J2, 140UE-J4, 140UE-J7, 140M-J8 See the Appendix

## THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB 14048.2-2008

This is to certify that the above mentioned products have met the requirements of implementation rules for compulsory certification(REF NO. CNCA-01C-011:2007).

Date of issue: May.13,2011      Date of expiry: Apr.19,2015

Validity of this certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

Date of original certification: Jun.30,2008

This certificate can be verified through CNCA's website: [www.cnca.gov.cn](http://www.cnca.gov.cn)



President:

Wang Kejiao



**CHINA QUALITY CERTIFICATION CENTRE**

Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China

<http://www.cqc.com.cn>



# 中国国家强制性产品认证证书

附录:

第 1 页 共 1 页

证书编号: 2008010307282409

纸号: 401620

140UE-J2,140UE-J4,140UE-J7,140M-J8

Ue:AC240V/415V/690V;DC250V(仅热磁式);

In:70A,80A,90A,100A,110A,125A,150A,160A,175A,200A,225A,

250A(热磁式);50A,100A,160A,250A(电子式);

140UE-J2:AC240V:Ics=Icu:65kA;AC415V:Ics=Icu:25kA;

AC690V:Ics:6kA;Icu:12kA;DC250V:Ics=Icu:10kA;

140UE-J4:AC240V:Ics=Icu:85kA;AC415V:Ics=Icu:40kA;

AC690V:Ics:6kA;Icu:12kA;DC250V:Ics=Icu:22kA;

140UE-J7:AC240V:Ics=Icu:100kA;AC415V:Ics:53kA;Icu:70kA;

AC690V:Ics:7kA;Icu:14kA;DC250V:Ics=Icu:22kA;

140M-J8:AC240V:Ics=Icu:100kA;AC415V:Ics:53kA;Icu:70kA;

AC690V:Ics:7kA;Icu:14kA;DC250V:Ics=Icu:22kA;

过电流脱扣器类型:热磁式,电子式;使用类别:A 类;

3P,4P(140UE-J2,140UE-J4,140UE-J7);3P(140M-J8)

注: 此附录与证书同时使用时有效。



主任:

中国质量认证中心

中国·北京·南四环西路 188 号 9 区 100070

<http://www.cqc.com.cn>

