



# CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

No. : 2009010304342158

## NAME AND ADDRESS OF THE APPLICANT

Rockwell Automation Inc.  
1201 South Second Street, Milwaukee, WI 53204, USA

TRADE MARK: ALLEN-BRADLEY

## NAME AND ADDRESS OF THE MANUFACTURER

Rockwell Automation AG  
Buchserstrasse 35, CH-5001 Aarau, Switzerland

## NAME AND ADDRESS OF THE FACTORY

Rockwell Automation AG  
Buchserstrasse 35, CH-5001 Aarau, Switzerland

## NAME, MODEL AND SPECIFICATION

Contactor

100-K..., 104-K...; See the Appendix

## THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB14048.4-2003

THIS IS TO CERTIFY THAT THE ABOVE MENTIONED PRODUCTS HAVE QUALIFIED FOR THE REQUIREMENTS OF IMPLEMENTATION RULES FOR COMPULSORY CERTIFICATION

ISSUED DATE: May. 08, 2009

THE VALIDITY OF THE CERTIFICATE DEPEND ON THE FOLLOW UP INSPECTION BY THE CERTIFICATION BODY AT REGULAR INTERVALS



President:

Wang Kejiao

CHINA QUALITY CERTIFICATION CENTRE

Section 9, No. 188, Nansihuan Xilu, Beijing 100070 P.R. China

<http://www.cqc.com.cn>



Q 0082381



# 中国国家强制性产品认证证书

证书编号: 2009010304342158

## 申请人名称及地址

罗克韦尔自动化  
1201 South Second Street, Milwaukee, WI 53204, USA

商标: ALLEN-BRADLEY

## 制造商名称及地址

Rockwell Automation AG  
Buchserstrasse 35, CH-5001 Aarau, Switzerland

## 生产企业名称及地址

Rockwell Automation AG  
Buchserstrasse 35, CH-5001 Aarau, Switzerland

## 产品名称和系列、规格、型号

接触器

100-K..., 104-K...; 详见参数附件

## 产品标准和技术要求

GB14048.4-2003

上述产品符合强制性产品认证实施规则的要求, 特发此证。

发证日期: 2009年05月08日

本证书的有效性依据发证机构的定期监督获得保持。



主任:

中国质量认证中心

中国·北京·南四环西路188号9区100070

<http://www.cqc.com.cn>



Q 0082381



# 中国国家强制性产品认证证书

附录:

共 2 页, 第 1 页

Appendix:

Page 1 of 2

证书编号: 2009010304342158

纸号: 82381

Type of contactor			100-K05* 104-K05*	100-K09* 104-K09*	100-K12* 104-K12*
AC-1					
le, 40°C	≤690VAC	[A]	20	20	20
AC-2 / AC-3 / AC-4					
le	AC200V	[A]	6.9	7.8	11
	AC230V	[A]	6.3	11.3	11.3
	AC240V	[A]	6.3	11.3	11.3
	AC400V	[A]	4.9	8.5	11.5
	AC415V	[A]	4.9	8.5	11.5
	AC460V	[A]	4.8	7.6	11
	AC500V	[A]	3.9	6.8	9.2
	AC575V	[A]	3.9	6.1	9
	AC690V	[A]	2.8	4.9	6.7
Pe	AC230V	[kW]	1.5	3	3
	AC240V	[kW]	1.5	3	3
	AC400V	[kW]	2.2	4	5.5
	AC415V	[kW]	2.2	4	5.5
	AC500V	[kW]	2.2	4	5.5
	AC690V	[kW]	2.2	4	5.5
AC-4 at approximately 200000 operations					
le	AC230V	[A]	2.6	3.3	3.3
	AC400V	[A]	2	2.7	3.6
	AC500V	[A]	1.5	2.2	2.9
	AC690V	[A]	1.1	1.6	2.1
Pe	AC230V	[kW]	0.55	0.75	0.75
	AC400V	[kW]	0.75	1.1	1.5
	AC500V	[kW]	0.75	1.1	1.5
	AC690V	[kW]	0.75	1.1	1.5

注: 此附录与证书同时使用时有效。



主任:

中国质量认证中心

中国·北京·南四环西路188号9区 100070

<http://www.cqc.com.cn>



Allen-Bradley PLCs



# 中国国家强制性产品认证证书

附录:

共 2 页, 第 2 页

Appendix:

Page 2 of 2

证书编号: 2009010304342158

纸号: 82381

Type of contactor			100-K05*200 100-K05*300 100-K05*400	100-K09*200 100-K09*300 100-K09*400	100-K12*200 100-K12*300 100-K12*400
AC-1					
le, 40°C	≤690VAC	[A]	20	20	20
AC-2 /AC-3					
le	AC230V	[A]	6.3	11.3	11.3
	AC400V	[A]	4.9	8.5	11.5
	AC500V	[A]	3.9	6.8	9.2
	AC690V	[A]	2.8	4.9	6.7
Pe	AC230V	[kW]	1.5	3	3
	AC400V	[kW]	2.2	4	5.5
	AC500V	[kW]	2.2	4	5.5
	AC690V	[kW]	2.2	4	5.5

I<sub>th</sub>=20A

Us: AC:12V 50/60Hz, 24V 50/60Hz, 32V 50/60Hz, 36V 50/60Hz, 42V 50/60Hz, 48V 50/60Hz, 60V 50/60Hz, 70V 50/60Hz, 110V 50 / 120V 60Hz, 127V 50/60Hz, 135V 50/60Hz, 200...220V 50/60Hz, 230V 50/60Hz, 240V 50/60Hz, 250V 50/60Hz, 380...400V 50Hz, 400V 50/60Hz, 415V 50/60Hz, 440V 50 / 480V 60Hz,

DC: 9 (6...12) V, 12 (7.5...15) V, 24 (17...30)V, 30V, 36V, 48V, 60V, 42V, 80V, 110 (93.5... 137.5)V, 120V, 125V, 220V;  
3P, 4P

注: 此附录与证书同时使用时有效。



主任:

中国质量认证中心

中国 · 北京 · 南四环西路 188 号 9 区 100070

http://www.cqc.com.cn

