

中国国家强制性产品认证证书

证书编号: 2010010301417147

委托人名称、地址

罗克韦尔自动化
1201 South Second Street, Milwaukee WI 53204, USA

生产者(制造商)名称、地址

罗克韦尔自动化
1201 South Second Street, Milwaukee WI 53204, USA

生产企业名称、地址

罗克韦尔自动化控制集成(上海)有限公司
上海市浦东新区创业路565号, T20-2通用厂房

产品名称和系列、规格、型号

低压成套开关设备
CENTERLINE 2500 主母线: In=4000A~2500A, Icw=80kA; 配电母
线: In=600A, Icw=50kA; Ue=690V, Ui=750V; 50Hz; IP42, IP40

产品标准和技术要求

GB 7251.1-2005

上述产品符合强制性产品认证实施规则
CNCA-01C-010: 2007的要求, 特发此证。

发证日期: 2010年07月06日 有效期至: 2015年07月06日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

本证书的相关信息可通过国家认监委网站www.cnca.gov.cn查询



主任:


中国质量认证中心

中国·北京·南四环西路188号9区 100070

<http://www.cqc.com.cn>



Q 0215508



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

No. : 2010010301417147

NAME AND ADDRESS OF THE APPLICANT

Rockwell Automation Inc.
1201 South Second Street, Milwaukee WI 53204, USA

NAME AND ADDRESS OF THE MANUFACTURER

Rockwell Automation Inc.
1201 South Second Street, Milwaukee WI 53204, USA

NAME AND ADDRESS OF THE FACTORY

Rockwell Automation Control Solution (Shanghai) Limited
T20-2 building, 565 Chuangye Road, Pudong, Shanghai 201201

NAME, MODEL AND SPECIFICATION

Low-voltage Switchgear Assemblies
CENTERLINE 2500 主母线: In=4000A~2500A, Icw=80kA; 配电母
线: In=600A, Icw=50kA; Ue=690V, Ui=750V; 50Hz; IP42, IP40

THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB 7251.1-2005

This is to certify that the above mentioned products have met the requirements of implementation rules for compulsory certification (REF NO. CNCA-01C-010:2007).

Date of issue: Jul. 06, 2010 Date of expiry: Jul. 06, 2015

Validity of this certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

This certificate can be verified through CNCA's website: www.cnca.gov.cn



President:

Wang Kejiao

CHINA QUALITY CERTIFICATION CENTRE

Section 9, No. 188, Nansihuan Xilu, Beijing 100070 P.R. China

<http://www.cqc.com.cn>

