



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

No. : 2011010309461413

NAME AND ADDRESS OF THE APPLICANT

ROCKWELL AUTOMATION Inc.
1201 SOUTH SECOND STREET, MILWAUKEE WI 53204, USA

NAME AND ADDRESS OF THE MANUFACTURER

TAIAN Technology (Wuxi) Co., Ltd.
Block 65-C, Wuxi National High-Tech Industry Development Zone, Wuxi, Jiangsu
Province, P. R. China

NAME AND ADDRESS OF THE FACTORY

TAIAN Technology (Wuxi) Co., Ltd.
1201 SOUTH SECOND STREET, MILWAUKEE WI 53204, USA

NAME, MODEL AND SPECIFICATION

Thermal Overload Relay

193-K, 193-T1A, 193-T1B Ue: AC690; Ie: 193-K: 0.10~0.16A, 0.16~0.25A, 0.25~0.4A, 0.35~0.50A, 0.45~0.63A, 0.55~0.8A, 0.75~1.0A, 0.9~1.3A, 1.1~1.6A, 1.4~2.0A, 1.8~2.5A, 2.3~3.2A, 2.9~4.0A, 3.5~4.8A, 4.5~6.3A, 5.5~7.5A, 7.2~10A, 9~12.5A; 193-T1A: 0.10~0.16A, 0.16~0.25A, 0.25~0.4A, 0.35~0.50A, 0.45~0.63A, 0.55~0.8A, 0.75~1.0A, 0.9~1.3A, 1.1~1.6A, 1.4~2.0A, 1.8~2.5A, 2.3~3.2A, 2.9~4.0A, 3.5~4.8A, 4.5~6.3A, 5.5~7.5A, 7.2~10A, 9~12.5A, 11.3~16A, 15~20A, 17.5~21.5A, 21~25A; 193-T1B: 15~20A, 17.5~21.5A, 21~25A, 24.5~30A, 29~36A, 33~38A; Release class: 10A; Poles: 2P, 3P; Auxiliary Contacts: AC-15: Ue/Ie: 120V/6A, 240V/3A, 380V/1.9A, 480V/1.5A, 500V/1.4A, 600V/1.2A; DC-13: Ue/Ie: 125V/0.55A, 250V/0.27A

THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB 14048.4-2003

This is to certify that the above mentioned products have met the requirements of implementation rules for compulsory certification (REF NO. CNCA-01C-011:2007).

Date of issue: Feb. 28, 2011 Date of expiry: Dec. 06, 2015

Validity of this certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

This certificate can be verified through CNCA's website: www.cnca.gov.cn



President:

Wang Kejiao

CHINA QUALITY CERTIFICATION CENTRE

Section 9, No. 188, Nansihuan Xilu, Beijing 100070 P.R. China

<http://www.cqc.com.cn>



Q 0363928