



Wiring Kinetix 6000 Servo Drive to Gettys SX Two-Pole Resolver Based Motors

About This Publication

This publication provides tables for wiring the flying leads from a Gettys SX motor with a two-pole resolver to a Kinetix 6000 drive.

Contact Gettys (<http://www.elwood.com/gettys>) for motor installation instructions

IMPORTANT

Be sure to correctly connect shields, and ground the motor frame.

Wiring the Power Connections

Kinetix 6000 Drive	Gettys Power	
Terminal	Wire Color	Signal
U	Black	Phase A
V	White	Phase B
W	Red	Phase C
Ground	Green/Yellow	Ground
Wire to MF-16 ⁽¹⁾	Blue	Over Temp
Wire to MF-17 ⁽¹⁾	Blue	Over Temp

⁽¹⁾ Terminate with a Motor Feedback Connector (catalog number 2090-K6CK-D15MF).

Wiring the Resolver Connections

Kinetix 6000 Drive		Gettys Resolver		
Signal	MF-Pin #	Wire Color	Signal	Notes
Sine+	1	Yellow	SIN+ (S2)	—
Sine-	2	Blue	SIN- (S4)	—
Cos+	3	Brown	COS+ (S1)	—
Cos-	4	Black	COS- (S3)	—
Resolver Excitation	5	Gray	REF+ (R1)	—
Resolver Excitation	10	White	REF- (R2)	—
Overtemp ⁽¹⁾	16	Blue	Over Temp	From Motor Power Cable
Overtemp ⁽¹⁾	17	Blue	Over Temp	
—	Connector Shield	Drain Wire/Shield	—	—

⁽¹⁾ Kinetix 6000 drive requires the use of a Motor Feedback Connector (catalog number 2090-K6CK-D15MF) with thermal-switch filter-terminals to provide Over Temp signal termination. Refer to Wiring the Power Connections on page 1.

Allen-Bradley, Kinetix, and Rockwell Automation are trademarks of Rockwell Automation, Inc.

Trademarks not belonging to Rockwell Automation are the property of their respective companies.

www.rockwellautomation.com

Power, Control and Information Solutions Headquarters

Americas: Rockwell Automation, 1201 South Second Street, Milwaukee, WI 53204-2496 USA, Tel: (1) 414.382.2000, Fax: (1) 414.382.4444

Europe/Middle East/Africa: Rockwell Automation, Vorstlaan/Boulevard du Souverain 36, 1170 Brussels, Belgium, Tel: (32) 2 663 0600, Fax: (32) 2 663 0640

Asia Pacific: Rockwell Automation, Level 14, Core F, Cyberport 3, 100 Cyberport Road, Hong Kong, Tel: (852) 2887 4788, Fax: (852) 2508 1846

Publication 2090-IN016A-EN-P - January 2007