



Ultra5000 Intelligent Positioning Drive Firmware Revision 1.10

Catalog Numbers 2098-IPD-005, 2098-IPD-010, 2098-IPD-020,
2098-IPD-005-DN, 2098-IPD-010-DN, 2098-IPD-020-DN

Enhancements

Revision 1.10 extends the gate switch deadtime to 3.0 microseconds in the Intelligent Power Module (IPM) function for series B drives. This change does not affect the Motion Library or user programs.

Refer to the Ultra5000 IPD Installation Manual Document Update, publication 2098-DU002, for additional information about the series B power module upgrade to the 500, 1000, and 2000 Watt Ultra5000 drives.

IMPORTANT

Earlier Ultra5000 firmware revisions may lack the initial zero after the decimal point when displayed. For example, the display may be 1.8 when the actual revision is 1.08.

Rockwell Automation Support

Rockwell Automation provides technical information on the Web to assist you in using its products. At <http://support.rockwellautomation.com>, you can find technical manuals, a knowledge base of FAQs, technical and application notes, sample code and links to software service packs, and a MySupport feature that you can customize to make the best use of these tools.

For an additional level of technical phone support for installation, configuration, and troubleshooting, we offer TechConnect Support programs. For more information, contact your local distributor or Rockwell Automation representative, or visit <http://support.rockwellautomation.com>.

Installation Assistance

If you experience a problem with a hardware module within the first 24 hours of installation, please review the information that's contained in this manual. You can also contact a special Customer Support number for initial help in getting your module up and running.

United States	1.440.646.3223 Monday – Friday, 8am – 5pm EST
Outside United States	Please contact your local Rockwell Automation representative for any technical support issues.

New Product Satisfaction Return

Rockwell tests all of its products to ensure that they are fully operational when shipped from the manufacturing facility. However, if your product is not functioning, it may need to be returned.

United States	Contact your distributor. You must provide a Customer Support case number (see phone number above to obtain one) to your distributor in order to complete the return process.
Outside United States	Please contact your local Rockwell Automation representative for return procedure.

Allen-Bradley, Rockwell Automation, and Ultra5000 are trademarks of Rockwell Automation, Inc.

www.rockwellautomation.com

Power, Control and Information Solutions Headquarters

Americas: Rockwell Automation, 1201 South Second Street, Milwaukee, WI 53204-2496 USA, Tel: (1) 414.382.2000, Fax: (1) 414.382.4444

Europe/Middle East/Africa: Rockwell Automation, Vorstlaan/Boulevard du Souverain 36, 1170 Brussels, Belgium, Tel: (32) 2 663 0600, Fax: (32) 2 663 0640

Asia Pacific: Rockwell Automation, Level 14, Core F, Cyberport 3, 100 Cyberport Road, Hong Kong, Tel: (852) 2887 4788, Fax: (852) 2508 1846

Publication 2098-RN019B-EN-P — September 2006

Supersedes Publication 2098-RN019A-EN-P August 2006

Copyright © 2006 Rockwell Automation, Inc. All rights reserved. Printed in the U.S.A.