



THE CIRCUIT IS TYPICAL OF A SIZE 1-2 BUL 2106 FVR STARTER WITH 120 VOLT SEPARATE CONTROL

- OPTIONS:
- 1 N.O. AUXILIARY CONTACT ON EACH STARTER
  - 1 N.O. AUXILIARY CONTACT ON THE DISCONNECT

A COMPLETE AND ACCURATE REPRESENTATION OF THE CIRCUIT DEPENDS ON THE SIZE AND OPTIONS ORDERED.

NOTES

1 REMOTE DEVICE

2 ADDITIONAL CONTROL CIRCUIT OVERCURRENT PROTECTION MAY BE REQUIRED WHEN THE CONTROL CIRCUIT CONDUCTORS EXTEND BEYOND THE ENCLOSURE. REFER TO NATIONAL ELECTRICAL CODE.

References		BUL. 2106 SIZE 1-2		
Revision		TYPE B		
Release	Dimensions Apply Before Surface Treatment			
1 06/15/01	Tolerances Unless Otherwise Specified			
	2 Place Decimal ±.02			
	3 Place Decimal ±.005			
	Angles ±1			
Refer. Book	Dr.	Date	Sheet 1 Of 1	
	Chkd.	Date	Dwg Size C	
	Appd.	Date	2106WB006	