



THE CIRCUIT IS TYPICAL OF A SIZE 1 BUL 2112 FVNR STARTER WITH 120 VOLT SEPARATE CONTROL OPTIONS:

- 1 N.O. AUXILIARY CONTACT ON THE DISCONNECT
- 1 N.O. AUXILIARY CONTACT ON THE STARTER
- 1 N.C. AUXILIARY CONTACT ON THE STARTER

A COMPLETE AND ACCURATE REPRESENTATION OF THE CIRCUIT DEPENDS ON THE SIZE AND OPTIONS ORDERED.

NOTES

- [1] REMOTE DEVICE
- [2] ADDITIONAL CONTROL CIRCUIT OVERCURRENT PROTECTION MAY BE REQUIRED WHEN THE CONTROL CIRCUIT CONDUCTORS EXTEND BEYOND THE ENCLOSURE. REFER TO NATIONAL ELECTRICAL CODE.

References		Bul 2112 FVNR		
Revision	Release	Dimensions Apply Before Surface Treatment	Dimensions in Inches Tolerances Unless Otherwise Specified	
1	06/15/01	2 Place Decimal ±.02	3 Place Decimal ±.005	
		Angles ±1		
Refer. Book		Dr.	Date	
		Chkd.	Date	
		Appd.	Date	