



X	1	2	3	4	5	6	7	8	9	T	T	T	1	2	3	TB
---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	----

THE CIRCUIT IS TYPICAL OF A SIZE 1 BUL 2112 FVNR STARTER WITH TRANSFORMER CONTROL

OPTIONS:

- A 480/120V CONTROL TRANSFORMER WITH PRIMARY FUSES
- 1 N.O. AUXILIARY CONTACT ON THE STARTER
- 1 N.C. AUXILIARY CONTACT ON THE STARTER
- 1 'ON' PUSH-TO-TEST PILOT LIGHT (RED)
- 1 'OFF' PUSH-TO-TEST PILOT LIGHT (GREEN)
- 1 DeviceNET STARTER AUXILIARY MODULE
- 1 'HAND-OFF-AUTO' SELECTOR SWITCH

A COMPLETE AND ACCURATE REPRESENTATION OF THE CIRCUIT DEPENDS ON THE SIZE AND OPTIONS ORDERED.

**NOTES**

1  
REMOTE DEVICE

References		Dimensions Apply Before Surface Treatment	Bul 2112 FVNR	
Revision	Release		Dr.	Date
1	06/15/01	2 Place Decimal ±.02	Chkd.	Date
		3 Place Decimal ±.005	Appd.	Date
		Angles ±1		

**Allen-Bradley**  
**Rockwell Automation**

Sheet 1 Of 1  
Dwg Size C  
2112WB021