



THE CIRCUIT IS TYPICAL OF A 200 AMP BUL 2113 FVNR VACUUM STARTER WITH 120 VOLT SEPARATE CONTROL
A COMPLETE AND ACCURATE REPRESENTATION OF THE CIRCUIT DEPENDS ON THE RATING AND OPTIONS ORDERED.

NOTES

- 1 REMOTE DEVICE
- 2 ADDITIONAL CONTROL CIRCUIT OVERCURRENT PROTECTION MAY BE REQUIRED WHEN THE CONTROL CIRCUIT CONDUCTORS EXTEND BEYOND THE ENCLOSURE. REFER TO NATIONAL ELECTRICAL CODE.

References		Bul 2113 FVNR (VACUUM)			
Revision		Dimensions Apply Before Surface Treatment		Dr. _____ Date _____ Chkd. _____ Date _____ Appd. _____ Date _____	
Release		Dimensions in Inches Tolerances Unless Otherwise Specified			
1	06/15/01	2 Place Decimal ± .02		Sheet 1 Of 1	
		3 Place Decimal ± .005		Dwg Size C	
		Angles ± 1		2113WB024	
Refer. Book				P.C.P. AutoCAD	