



THE CIRCUIT IS TYPICAL OF A 200 AMP BUL 2113 FVNR VACUUM STARTER WITH 120 VOLT SEPARATE CONTROL OPTIONS:  
 - 1 N.O. AUXILIARY CONTACT IN THE CIRCUIT BREAKER

A COMPLETE AND ACCURATE REPRESENTATION OF THE CIRCUIT DEPENDS ON THE RATING AND OPTIONS ORDERED.

**NOTES**

- [1] REMOTE DEVICE
- [2] ADDITIONAL CONTROL CIRCUIT OVERCURRENT PROTECTION MAY BE REQUIRED WHEN THE CONTROL CIRCUIT CONDUCTORS EXTEND BEYOND THE ENCLOSURE. REFER TO NATIONAL ELECTRICAL CODE.
- INTERNAL CB DEVICES SUPPLIED WITH UNMOUNTED CONNECTION BLOCKS.

References		Bul 2113 FVNR (VACUUM)		
Revision		Dimensions Apply Before Surface Treatment		
Release		Dimensions in Inches Tolerances Unless Otherwise Specified		
1	06/15/01	2 Place Decimal ± .02		Dr.
		3 Place Decimal ± .005		Chkd.
		Angles ± 1		Appd.
Refer. Book				Date

