



A




B


C



D



E



F

THE CIRCUIT IS TYPICAL OF A 200 AMP BUL 2113 FVNR VACUUM STARTER WITH 120 VOLT SEPARATE CONTROL OPTIONS:

- 1 SURGE SUPPRESSOR ON THE STARTER COIL
- 1 CONTROL CIRCUIT FUSE
- 1 N.O. AUXILIARY CONTACT ON THE CIRCUIT BREAKER

A COMPLETE AND ACCURATE REPRESENTATION OF THE CIRCUIT DEPENDS ON THE RATING AND OPTIONS ORDERED.

**NOTES**

- ☐ REMOTE DEVICE
- ☒ THIS IS AN EXTERNAL CIRCUIT BREAKER AUXILIARY AND SHOULD NOT BE USED FOR BREAKER TRIP INDICATION.

H

References		Bul 2113 FVNR (VACUUM)		
Revision	Release	Dimensions Apply Before Surface Treatment		
1	06/15/01	Dimensions in Inches Tolerances Unless Otherwise Specified		
		2 Place Decimal ± .02		
		3 Place Decimal ± .005		
Refer. Book		Angles ± 1	Dr. Chkd. Appd.	Date Date Date
				Sheet 1 Of 1 Dwg Size C 2113WB027

Allen-Bradley Parts