



THE CIRCUIT IS TYPICAL OF A SIZE 4 BUL 2172 RVAT STARTER WITH TRANSFORMER CONTROL
 OPTIONS:
 - A 480/120V CONTROL TRANSFORMER WITH PRIMARY FUSES
 A COMPLETE AND ACCURATE REPRESENTATION OF THE CIRCUIT DEPENDS ON THE SIZE AND OPTIONS ORDERED.

X	1	1	2	3	5	1	1	1	1	1	TB
2	A	B	A	A		1	3	4	5	6	

NOTES

- [1] REMOTE DEVICE
- [2] TIME DELAY SETTING MUST BE GREATER THAN SETTING OF "2S".

References		BUL. 2172 SIZE 4		
Revision		TYPE B		
Release	Dimensions Apply Before Surface Treatment	Tolerances Unless Otherwise Specified		Dr. _____ Date _____ Chkd. _____ Date _____ Appd. _____ Date _____
1 08/20/01	2 Place Decimal ± .02	3 Place Decimal ± .005		
	Angles ± 1			
Refer. Book				
			Sheet 1 Of 1	Dwg Size C 2172WB006
			P.C.P. AutoCAD	

Allen-Bradley Drives