

THE CIRCUIT IS TYPICAL OF A SIZE 4 BUL 2172 RVAT STARTER WITH TRANSFORMER CONTROL OPTIONS:



- A 480/120V CONTROL TRANSFORMER WITH PRIMARY FUSES
- 2 N.O. AND 2 N.C. AUXILIARY CONTACTS (USING BUL 700CF RELAY)

A COMPLETE AND ACCURATE REPRESENTATION OF THE CIRCUIT DEPENDS ON THE SIZE AND OPTIONS ORDERED.

NOTES

[1] REMOTE DEVICE

[2] TIME DELAY SETTING MUST BE GREATER THAN SETTING OF "2S".



THE CIRCUIT IS TYPICAL OF A SIZE 4 BUL 2172 RVAT STARTER WITH TRANSFORMER CONTROL

- A 480/120V CONTROL TRANSFORMER WITH PRIMARY FUSES
- 2 N.O. AND 2 N.C. AUXILIARY CONTACTS (USING BUL 700CF RELAY)

A COMPLETE AND ACCURATE REPRESENTATION OF THE CIRCUIT DEPENDS ON THE SIZE AND OPTIONS ORDERED.

NOTES

[1] REMOTE DEVICE

[2] TIME DELAY SETTING MUST BE GREATER THAN SETTING OF "2S".

References		BUL. 2172 SIZE 4		 Rockwell Automation
Revision		TYPE B		
Release				
1 08/20/01				
Dimensions Apply Before Surface Treatment				Sheet 1 Of 1 Dwg Size C 2172WB09
Tolerances Unless Otherwise Specified				
2 Place Decimal ± .02				
3 Place Decimal ± .005				
Angles ± 1				Dr. _____ Date _____ Chkd. _____ Date _____ Appd. _____ Date _____
Refer. Book				