



THE CIRCUIT IS TYPICAL OF A SIZE 4 BUL 2172 RVAT STARTER WITH TRANSFORMER CONTROL
 OPTIONS:

- A 480/120V CONTROL TRANSFORMER WITH PRIMARY FUSES
- 1 'HAND-OFF-AUTO' SELECTOR SWITCH
- 1 'RUN' PUSH-TO-TEST PILOT LIGHT (RED)
- 2 N.O. AND 2 N.C. AUXILIARY CONTACTS (USING BUL 700CF RELAY)

A COMPLETE AND ACCURATE REPRESENTATION OF THE CIRCUIT DEPENDS ON THE SIZE AND OPTIONS ORDERED.

NOTES

[1] REMOTE DEVICE

[2] TIME DELAY SETTING MUST BE GREATER THAN SETTING OF "2S".

References		BUL. 2172 SIZE 4		 Rockwell Automation
Revision		TYPE B		
Release		Dr.		
1 08/20/01		Date		
Dimensions Apply Before Surface Treatment		Date		Sheet 1 Of 1 Dwg Size C 2172WB011
Dimensions in Inches Tolerances Unless Otherwise Specified		Date		
2 Place Decimal ± .02		Date		
3 Place Decimal ± .005		Appd.		
Refer. Book		Angles ± 1		

