



THE CIRCUIT IS TYPICAL OF A SIZE 4 BUL 2172 RVAT STARTER WITH TRANSFORMER CONTROL

- OPTIONS:
- A 480/120V CONTROL TRANSFORMER WITH PRIMARY FUSES
 - 1 DeviceNET STARTER AUXILIARY MODULE WITH 120V INPUTS AND OUTPUTS
 - 1 'HAND-OFF-AUTO' SELECTOR SWITCH
 - 1 'RUN' PILOT LIGHT (RED)
 - 1 'OFF' PILOT LIGHT (GREEN)
 - 2 N.O. AND 2 N.C. AUXILIARY CONTACTS (USING BUL 700CF RELAY)
 - 1 SMP-1 SOLID STATE OVERLOAD RELAY

NOTES

- [1] REMOTE DEVICE
- [2] TIME DELAY SETTING MUST BE GREATER THAN SETTING OF "2S".
- [3] INPUT TO "IN Ø" TO BE DETERMINED BY USER.

A COMPLETE AND ACCURATE REPRESENTATION OF THE CIRCUIT DEPENDS ON THE SIZE AND OPTIONS ORDERED.

References		Dimensions Apply Before Surface Treatment
Revision	Release	
1	08/20/01	2 Place Decimal ±.02
		3 Place Decimal ±.005
		Angles ±1

BUL. 2172 SIZE 4	
TYPE B	
Dr.	Date
Chkd.	Date
Appd.	Date

Allen-Bradley
Rockwell Automation

Sheet 1 Of 1
 Dwg Size C
2172WB014