



NOTES

- [1] AMPS NAMEPLATE RATIO
 - AMPS EFFECTIVE RATIO WITH
 - PRIMARY TURNS
 - SECONDARY TURNS
- BE SURE TO CONNECT PER POLARITY MARKINGS. SECONDARY CONNECTIONS OF CURRENT TRANSFORMER MUST BE CONNECTED TO A LOAD OR SHORTED TOGETHER AND GROUNDED TO AVOID A HIGH VOLTAGE ACROSS SECONDARY LEADS.
- CUSTOMER IS TO MOUNT AND WIRE CURRENT TRANSFORMERS.
- ON 6 S.F. INCOMING LINE LUG COMPARTMENTS, THE CURRENT TRANSFORMERS ARE FACTORY MOUNTED AND WIRED.

THE CIRCUIT IS TYPICAL OF A BUL 2191 INCOMING MAIN LUG UNIT
 OPTIONS:
 - 1 ANALOG PANEL AMMETER WITH 2 CURRENT TRANSFORMERS

A COMPLETE AND ACCURATE REPRESENTATION OF THE CIRCUIT DEPENDS ON THE SIZE AND OPTIONS ORDERED.

References		Bul 2191M		
Revision	Dimensions Apply Before Surface Treatment	Dr.	Date	
Release	Dimensions in Inches Tolerances Unless Otherwise Specified	Chkd.	Date	
1 06/27/01	2 Place Decimal ± .02	Appd.	Date	
	3 Place Decimal ± .005			
	Angles ± 1			
Refer. Book				Sheet 1 Of 1 Dwg Size C 2191MWB003