



THE CIRCUIT IS TYPICAL OF A 16 AMP BUL 2407 FVR STARTER WITH 120 VOLT SEPARATE CONTROL

A COMPLETE AND ACCURATE REPRESENTATION OF THE CIRCUIT DEPENDS ON THE SIZE AND OPTIONS ORDERED.

**NOTES**

- [1] REMOTE DEVICE
- [2] ADDITIONAL CONTROL CIRCUIT OVERCURRENT PROTECTION MAY BE REQUIRED WHEN THE CONTROL CIRCUIT CONDUCTORS EXTEND BEYOND THE ENCLOSURE. REFER TO NATIONAL ELECTRICAL CODE.
- [3] DO NOT USE AUTOMATIC RESET MODE IN APPLICATIONS WHERE UNEXPECTED AUTOMATIC RESTART OF THE MOTOR CAN CAUSE INJURY TO PERSONS OR DAMAGE TO EQUIPMENT.

References		BUL. 2407 16 AMP		
Revision	Release	Dimensions Apply Before Surface Treatment	TYPE B	
1	08/28/01	Dimensions in Inches Tolerances Unless Otherwise Specified	Dr.	Date
		2 Place Decimal ± .02	Chkd.	Date
		3 Place Decimal ± .005	Appd.	Date
Refer. Book		Angles ± 1		
			Sheet	1 Of 1
			Dwg Size	C
			2407WB001	