



THE CIRCUIT IS TYPICAL OF A 16 AMP BUL 2407 FVR STARTER WITH TRANSFORMER CONTROL
 OPTIONS:

- A 480/120V CONTROL TRANSFORMER WITH PRIMARY FUSES
- 1 'FORWARD' PUSH-TO-TEST PILOT LIGHT (RED)
- 1 'REVERSE' PUSH-TO-TEST PILOT LIGHT (RED)
- 2 N.O. AUXILIARY CONTACTS ON EACH STARTER
- 2 N.C. AUXILIARY CONTACTS ON EACH STARTER

A COMPLETE AND ACCURATE REPRESENTATION OF THE CIRCUIT DEPENDS ON THE SIZE AND OPTIONS ORDERED.

NOTES

- [1] REMOTE DEVICE
- [2] DO NOT USE AUTOMATIC RESET MODE IN APPLICATIONS WHERE UNEXPECTED AUTOMATIC RESTART OF THE MOTOR CAN CAUSE INJURY TO PERSONS OR DAMAGE TO EQUIPMENT.

References		BUL. 2407 16 AMP		
Revision		TYPE B		
Release	Dimensions Apply Before Surface Treatment			
1 08/28/01	Tolerances Unless Otherwise Specified			
	2 Place Decimal ± .02			
	3 Place Decimal ± .005	Dr.	Date	Sheet 1 Of 1
	Angles ± 1	Chkd.	Date	Dwg Size C
Refer. Book		Appd.	Date	2407WB013