



### **Bulletin 2707 MicroView Operator Interface, Series B (Catalog Number 2707-MVH232, -MVP232)**

#### **Release Contents**

This Release Note supports the introduction of Series B of the MicroView Operator Interface.

#### **Agency Certifications**

The MicroView Operator Interface now has the following agency certifications: CSA Class 1 Division 2 Hazardous Location, UL Class 1 Division 2 Hazardous Location. It also has CE certification. This equipment is suitable for use in Class 1, Division 2, Groups A, B, C, and D or non-hazardous locations only.

#### **Installation Information**

Be certain to follow all directions for installing and connecting power to the MicroView module. These directions are found in the MicroView Operator Interface Module User Manual (Publication 2707-804).

When used in a hazardous environment, the ultimate enclosure must be in accordance with Class 1, Division 2 wiring methods as described in the National Electrical Code (ANSI/NFPA 70) and the Canadian Electrical Code.

All peripheral equipment must be suitable for the location in which it is used.

Use only a Class 2 power source as described in the National Electrical Code (ANSI/NFPA 70) and the Canadian Electrical Code. The recommended AC to DC adapters (2707-PS120, 2707-PS220) meet this requirement.

The MicroView module contains no user serviceable parts.



**ATTENTION:** USE ONLY WITH CLASS 2 POWER SOURCE LIMITED TO 30 VDC OPEN CIRCUIT AND 8A SHORT CIRCUIT.

**ATTENTION:** UTILISER AVEC UNE TENSION D'ALIMENTATION CLASSE 2 DE 30 VCC MAXI EN CIRCUIT OUVERT AVEC UN COURANT DE COURT-CIRCUIT DE 8A MAXI.

---

**ATTENTION:**

**EXPLOSION HAZARD:** DO NOT CONNECT OR DISCONNECT EQUIPMENT WHILE CIRCUIT IS LIVE UNLESS AREA IS KNOWN TO BE NON-HAZARDOUS.

**RISQUE D'EXPLOSION:** NE PAS BRANCHER OU DEBRANCHER TANT QUE LE CIRCUIT EST SOUS TENSION, A MOINS QU'IL NE S'AGISSE D'UN EMPLACEMENT NON DANGEREUX.

---

## European Union Directive Compliance

If this product is installed within the European Union or EFTA regions, the following regulations apply.

This apparatus is tested to meet Council Directive 89/336 Electromagnetic Compatibility (EMC) Standards:

- EN50081-1 Class (Residential) Emissions
- EN50082-2 Class A (Industrial) Immunity

## DECLARATION OF CONFORMITY

This Declaration of Conformity is suitable to the European Standard EN 45014, "General criteria for supplier's declaration of conformity." The basis for the criteria has been found in international documentation, particularly in: ISO/IEC Guide 22, 1982, "Information on manufacturer's declaration of conformity with standards or other technical specifications."

Allen-Bradley liability under this declaration is limited to that set forth in the current Allen-Bradley publication 6500, Terms and Conditions of Sale as well as similar publications from Allen-Bradley affiliates doing business in the European Community.

---

**Applied Council Directive(s):**  
**89/336/EEC Electromagnetic Compatibility Directive (EMC), and amending directives 91/263/EEC, 92/31/EEC, 93/68/EEC**

---

<p>We,  <b>Manufacturer: Allen-Bradley Company, Inc.</b>          1201 South 2nd Street          Milwaukee, WI 53204          U.S.A.</p>	<p><b>Authorized Representative in the Community (and location of Responsible Person):</b></p>	<p><b>Allen-Bradley, subsidiary of Rockwell International GmbH</b>          Düsseldorf Str. 15          D-42781 Haan Germany</p>
----------------------------------------------------------------------------------------------------------------------------------------------------------	------------------------------------------------------------------------------------------------	------------------------------------------------------------------------------------------------------------------------------------------

declare under our sole responsibility that the product(s):

**MicroView Operator Interface Products**  
**2707-MVH232, 2707-MVP232**  
**(series B or higher)**

---

to which this declaration relates is in conformity with the relevant provisions of the following standard(s) or other normative document(s):

**EN 50082-2:1995 EMC Generic Immunity Standard - Industrial**  
**EN 50081-1:1992 EMC Generic Emission Standard - Residential, Commercial, Light Industrial**

**Technical Information is maintained at:**  
**Allen-Bradley Company, Inc.**  
 1201 South Second Street  
 Milwaukee, Wisconsin 53204 U.S.A


---

We, the undersigned, hereby declare that the product(s) specified above conforms to the listed directive(s) and standard(s).

**Manufacturer**

Signature:   
 Full Name: Robert Gardiner  
 Position: Manager, Quality Engineering  
 Date: 19 JULY 1996

**Authorized Representative in the Community through its Responsible Person**

Signature:   
 Full Name: Viktor Schiffer  
 Position: Engineering Manager  
 Date: 1 August 1996



Allen-Bradley, a Rockwell Automation Business, has been helping its customers improve productivity and quality for more than 90 years. We design, manufacture and support a broad range of automation products worldwide. They include logic processors, power and motion control devices, operator interfaces, sensors and a variety of software. Rockwell is one of the worlds leading technology companies.

### Worldwide representation.



Argentina • Australia • Austria • Bahrain • Belgium • Brazil • Bulgaria • Canada • Chile • China, PRC • Colombia • Costa Rica • Croatia • Cyprus • Czech Republic • Denmark • Ecuador • Egypt • El Salvador • Finland • France • Germany • Greece • Guatemala • Honduras • Hong Kong • Hungary • Iceland • India • Indonesia • Ireland • Israel • Italy • Jamaica • Japan • Jordan • Korea • Kuwait • Lebanon • Malaysia • Mexico • Netherlands • New Zealand • Norway • Pakistan • Peru • Philippines • Poland • Portugal • Puerto Rico • Qatar • Romania • Russia-CIS • Saudi Arabia • Singapore • Slovakia • Slovenia • South Africa, Republic • Spain • Sweden • Switzerland • Taiwan • Thailand • Turkey • United Arab Emirates • United Kingdom • United States • Uruguay • Venezuela • Yugoslavia

Allen-Bradley Headquarters, 1201 South Second Street, Milwaukee, WI 53204 USA, Tel: (1) 414 382-2000 Fax: (1) 414 382-4444